

Transmission Company of Nigeria MEMORANDUM

Date:20/01/2025
To:NESI Stake holders.

From: GM(S0)

TCN CHQ Abuja

Ref: TW/Gm (so)/110.00/141/2025

RE: DECLARATION OF FORCE MAJEURE ON 132KV KATAMPE-CENTRAL AREA TRANSMISSION LINE 1 & 2

The Transmission Service Provider has requested the declaration of Force Majeure on **3KTP-KTP-CTA1**, citing the destruction carried out by vandals discovered during line patrol at Millennium Park Abuja, about (40M) of 1 X 500mm² xlpe underground cable on two lines were cut and taken away. This request, referenced in memo **TCN-ABJR/GM(T)/01/015/2025** has been reviewed according to Market Rule (MR) 48.8.4 and found valid.

As a result, System Operations (SO) now declares Force Majeure on the 132 kV Katampe – Central Area transmission Lines 1 and 2 effective from 16th Jan, 2025.

Engr. M.N Nwagu

General Manager (SO)